ONE POINT LESSON

Registration No.		DIP/ELEC/12-03-21
Theme	**Maintenance Standards of Electrical Switch Boxes, Panels & JBs.**	Posting expires: Basic knowledge Problem case examples Improvement case examples

Canopy optional if its in the outdoors and in the open .

Give the identification of the JB or Switch box

Absolutely air tight and locked

On every JB, Switch Box stick this warning label



Good rubber lining around will ensure proper sealing

Any cable inlet not used should be plugged.

Circuit diagram on the inside of the cover.

No peeling of paint . Touch up if any spot found.

All switches ,lamps breakers identifed.

All fuses ,breakers identified.

Spotlessly clean inside. Do not use blowers.

Panel box identifed.

All cable incoming & outgoing through gland only.

| Correspondence courses | | |